Air vents for bulkhead slots

North Elevator Tower

Deck EL. 1613.5

Top of Gate EL. 1610.0

Power Intake

Minimum Pool EL. 1445.0

Bottom of Gates EL. 1435.0

Sill EL. 1395.0

Future Power

⑥ 220 MW ⑤ 220 MW ④ 220 MW ③ 220 MW ② 90 MW ① 90 MW

EL. 1289.05

Corbel

EL. 1220.0

Crest EL. 1151.0

Intakes

FOREBAY
POWER INTAKE
Not To Scale

NOTES:

1. Top of gate shall be
   at elevation 1610.0 wh
   gates in the undershot
   Gate position shall not
   changed while turbines
   operating.

2. Undershot mode can b
   for pool elevations 14
   to 1600.0.